



Western

JOB HAZARD ANALYSIS - Task Specific

NEW

REVISED

WORKPLACE TASK TO BE ANALYSED

Clean-up of Broken Asbestos Transite Tiles

DEPARTMENT

Facilities Management

WESTERN JOB CLASSIFICATION*

Caretaker

REQUIRED EQUIPMENT AND/OR PERSONAL PROTECTIVE EQUIPMENT

Safety Shoes, Safety glasses, Gloves (respirator may be requested)

WESTERN HAZARD CATEGORY*

Energy/Tools or Equipment/Work Site Hazards

HAZARD TYPE*

Inhalation / Slip / Trip

LOSS POTENTIAL RATING*

Moderate

*refer to Stantec Specific Job Report

DATE:

March 17, 2021

WRITTEN BY:

Tony Hammoud

REVIEWED BY:

Building Managers

MGMT APPROVAL:

Chris Bumbacco

SEQUENCE OF TASK	POTENTIAL HAZARDS	ACTION OR PROCEDURE
Isolate affected area	tripping, falling	Wear proper PPE, Secure work area to prevent further damage to the broken tiles.
Assess damaged area	lose tiles falling	This JHA only addresses the clean-up of small amount of asbestos transite tile debris. It should be noted that FM Asbestos Work Procedures 11 and 12 must be followed if the damaged area is deemed as requiring more specialized asbestos removal expertise. Consult with your Lead Hand or Supervisor.
Prepare for cleaning	Overexertion /strain injuries	Spray broken tiles with amended water to help reduce the dust.
Clean-up broken tiles	Wet floor - slip hazard	Remove all broken tiles and tile fragments and place in a ridgid plastic bag. Wipe the wet floor with rags and place the rags in the plastic bag with the broken tiles.

Waste disposal	Strain / overexertion	Take the tile waste to a secure location and make arrangements with the Carpentry shop to transport the waste to the asbestos waste bin.
Special consideration		The worker may request a "Half-Face HEPA Respirator" prior to performing this task. In this case, the worker must be fit-tested with the right respirator by Occupational Health and Safety.